

BLUEARTH

BURDETT SOLAR PROJECT GLARE STUDY





BURDETT SOLAR PROJECT GLARE STUDY

BLUEARTH

DOCUMENT: VI

PROJECT NO: 191-02024-00

DATE: JULY 2019

WSP
405 18 ST SE
CALGARY, AB
CANADA, T2E 6J5

T: +1 403 248-9463
WSP.COM

REVISION HISTORY

Version	Issue Date	Author	Description
1	July 31, 2019	Alexander Medd	Glare assessment for the Burdett Solar Project in southern Alberta

SIGNATURES

PREPARED BY

Alexander Medd, EIT
Specialist, Power

REVIEWED BY

Rob Istchenko, P.Eng
Director, Power

DISCLAIMER

WSP Canada Inc. ("WSP") prepared this report solely for the use of the intended recipient, BluEarth, in accordance with the professional services agreement. In the event a contract has not been executed, the parties agree that the WSP General Terms for Consultant shall govern their business relationship which was provided to you prior to the preparation of this report.

The report is intended to be used in its entirety. No excerpts may be taken to be representative of the findings in the assessment.

The conclusions presented in this report are based on work performed by trained, professional and technical staff, in accordance with their reasonable interpretation of current and accepted engineering and scientific practices at the time the work was performed.

The content and opinions contained in the present report are based on the observations and/or information available to WSP at the time of preparation, using investigation techniques and engineering analysis methods consistent with those ordinarily exercised by WSP and other engineering/scientific practitioners working under similar conditions, and subject to the same time, financial and physical constraints applicable to this project.

WSP disclaims any obligation to update this report if, after the date of this report, any conditions appear to differ significantly from those presented in this report; however, WSP reserves the right to amend or supplement this report based on additional information, documentation or evidence.

WSP makes no other representations whatsoever concerning the legal significance of its findings.

The intended recipient is solely responsible for the disclosure of any information contained in this report. If a third party makes use of, relies on, or makes decisions in accordance with this report, said third party is solely responsible for such use, reliance or decisions. WSP does not accept responsibility for damages, if any, suffered by any third party because of decisions made or actions taken by said third party based on this report.

The original of this digital file will be kept by WSP for a period of not less than 10 years. As the digital file transmitted to the intended recipient is no longer under the control of WSP, its integrity cannot be assured. As such, WSP does not guarantee any modifications made to this digital file after its transmission to the intended recipient.

This limitations statement is considered an integral part of this report.



TABLE OF CONTENTS

1	INTRODUCTION	1
2	BACKGROUND	3
3	METHODOLOGY	5
4	RESULTS	6
5	CONCLUSIONS	8

TABLES

Table 1: Burdett Project Summary	1
Table 2: Analysis Assumptions.....	5
Table 3: Glare at Intersections.....	6
Table 4: Glare at Receptors.....	7

FIGURES

Figure 1: Burdett Project Site Map.....	2
Figure 2: Glare Assessment Plot.....	3

APPENDICES

A	Detailed Glare Results
---	------------------------

1 INTRODUCTION

WSP has performed an independent glare assessment for the Burdett Solar Project on behalf of BluEarth. The project is located approximately 70 km south-west of Medicine Hat, Alberta and 2 km to the south-east of Burdett. The project lands¹ (Approx. 200 Acres) consists of farm land and the terrain within the project lands is relatively simple. A map of the project site and the glare assessment points is shown in Figure 1. The project has several houses in the vicinity, a major highway to the north, gravel roads surrounding the project lands and several intersections. Table 1 summarizes additional project characteristics.²

Table 1: Burdett Project Summary

Project Size	29.93 MW _{DC}
Racking Style	30 Degree Fixed Tilt
Ground Clearance	1 m
Azimuth	180 Degrees (South)

¹ BluEarth, BUR_PanelFixed8p5m_BER_20180426.shp

² BluEarth, Burdett Site Assumptions 20181013.xlsx




Figure 1: Burdett Project Site Map

2 BACKGROUND

Photovoltaic (PV) solar panels generate electricity from sunlight; however, some of the light is reflected and can cause glint, a momentary flash of bright light and glare, a continuous source of bright light. Glare is typically associated with stationary objects which reflect sunlight for a longer duration. Reflections from solar panels have the potential to impair observers which may cause risk to public safety if a driver is affected.

The ocular impact of glare is a function of the radiation that reaches the retina and the apparent size of the source point. It is typically assumed that 50% of incoming radiation is absorbed prior to reaching the retina.³

The ocular impact of glare is classified into three qualitative categories⁴ based on the intensity and angle of incoming light as shown in Figure 2:

- Green: low potential for after image.
- Yellow: potential to cause a temporary after image.
- Red: potential to cause permanent damage.




Figure 2: Glare Assessment Plot

³ 'Methodology to Assess Potential Glint and glare Hazards from Concentrating Solar Power Plants: Analytical Models and Experimental Validation' Ho, 2011

⁴ 'Summary of Impact Analyses of Renewable Energy Technologies on Aviation and Airports' Ho, 2011

An after image is an image that continues to appear in one's vision after the exposure to the original image has ceased. Direct viewing of the sun has the potential to cause an after image. As shown in Figure 2, the retinal irradiance associated with direct viewing of the sun is below the level at which there is potential for permanent eye damage. Because sunlight does not cause retinal burn, permanent damage is not possible from the reflection from a solar panel.

Approximately 7% of incoming light must be reflected from a solar panel to cause an after image. The amount of light reflected is a function of the incident angle of the incoming light on the solar panel and the surface roughness. Under high angle of incidence up to 60% of incoming light can be reflected⁵ resulting in the potential for higher intensity glare at fixed tilt solar projects.

⁵ 'Assesment of Photovoltaic Surface texturing on Transmittance Effects and Glint/Glare Impacts' Yellowhair, 2015

3 METHODOLOGY

WSP used the ForgeSolar⁶ Solar Glare Hazard Analysis Tool (SGHAT) to complete the glare analysis. The program considers the angle of the panel, the path of the sun, the incoming radiation and the PV array shape and panel reflectivity characteristics when calculating the amount of glare at each input receptor point and path. The panels are modelled as infinitesimally small panels covering the entire defined array area reflecting sunlight in the trajectory of the input tilt and azimuth. The program has the following limitations resulting in conservative estimates of glare duration:

- Obstacles such as trees and buildings are not considered in the analysis.
- Row spacing and shading from panels is not considered.
- Reduction of reflectivity of the panel due to soiling is not considered.
- Path receptor glare is calculated based on the centroid of the array area.
- Receptors are modelled as greenhouses with windows on all sides. Building design may significantly change the number of hours a home is affected by glare.

Table 2 outlines additional key assumptions for the analysis.

Table 2: Analysis Assumptions

Peak Direct Normal Irradiance	1000 W/m ² varying by time of day
Ocular Transmission Coefficient	0.5
Pupil Diameter	0.002 m
Eye Focal Length	0.017 m

The output is a quantification of the amount of time glare is possible and the time of day most likely to be affected. Based on the manufacturer's specifications, the computation has assumed an anti reflective coating on the panels which reduces reflectivity by a small amount. There are no regulations for glare in Canada and limits for time spent in each glare category are not defined.

⁶ <https://www.forgesolar.com>

4 RESULTS

WSP calculated glare for houses identified by BluEarth, the nearby substation and cogeneration facility, nearby road intersections and a 2-mile 3° glide slope path at each approach to the Bow Island Airport. Path features and intersection point features were calculated at heights of 1.5 m to account for passenger vehicles and 3 m to account for trucks.

Results from the analysis are presented in Table 3 and Table 4 for the intensity, approximate times of day, time of year when glare is expected and maximum daily duration of glare for intersections and receptors at heights of 1.5 m and 3.0 m. Graphical results in Appendix A provide additional detail.

Table 3: Glare at Intersections

Intersection	Glare Intensity	Affected Months	Affected Times of Day (Approximate) (MST)	Maximum Daily Glare at 1.5 m (Minutes)	Maximum Daily Glare at 3.0 m (Minutes)
Hwy 3 and RR 122	None	-	-		
Hwy 3 and RR 123	None	-	-		
TWP 102 and RR 122	Yellow	March-September	6:45 AM	10	13
TWP 102 and RR 123	Yellow	March-September	6:00 PM	7	11
East Access Road Intersection	Yellow	March-September	6:00 PM	40	48
South Access Road Intersection	Yellow	March-October	7:00 AM and 6:00 PM	19	25

Due to high traffic volume, glare at intersections with Highway 3 and the rail line running parallel to Highway 3 north of the project are important points for consideration. There is no expected glare related to this project along any point of either Highway 3 or the rail line.

Similarly, no glare was calculated at the Bow Island Airport northeast of the project. The impact of glare on aviation outside the context of the Bow Island Airport was not considered within the scope of this assessment.

Glare was calculated at receptors surrounding the project. Receptor 1 was assumed to be 3 m tall based on field verification by BluEarth. Remaining houses and

industrial receptors were assumed to be 4.5 m tall to account for two-storey buildings. Three residential receptors experience glare. Both industrial receptors experience glare in the evening. Results are presented in Table 4.

Table 4: Glare at Receptors

Receptor	Assessment Height	Glare Intensity	Affected Months	Affected Time of Day (Approximate) (MST)	Maximum Daily Glare (Minutes)
1	3 m	Yellow	February-October	5:30 PM	44
2	4.5 m	Yellow	April-September	6:30 AM	18
3	4.5 m	None	-	-	-
4	4.5 m	None	-	-	-
5	4.5 m	None	-	-	-
6	4.5 m	None	-	-	-
7	4.5 m	Yellow	March-September	6:30 AM	11
8	4.5 m	None	-	-	-
Substation	4.5 m	Yellow	March-October	6:00 PM	33
Cogeneration Facility	4.5 m	Yellow	March-September	6:00 PM	17

5 CONCLUSIONS

INTERSECTIONS

The intersections along the high traffic volume routes including Highway three and the rail line to the north of Highway 3 are not expected to experience glare. Some of the minor intersections modeled near the project are expected to experience periods of yellow glare between the months of February and October and a maximum daily duration of 48 minutes. Consultation with traffic safety experts is recommended to ensure that the anticipated impacts are acceptable.

BOW ISLAND AIRPORT

The analysis identified no potential glare impacts at the Bow Island airport.



RECEPTORS

Yellow Glare is expected at three residential receptors as well as the adjacent substation and cogeneration facility between the months of February and October. The maximum daily duration of glare at these receptors is 44 minutes. The results are considered to be conservative due to fact that the analysis does not account for vegetation and assumes two-storey receptor heights. Consultation with the landowners and facility operators is recommended.



APPENDIX

A DETAILED GLARE RESULTS



Receptor 1 at 4.5 m





Receptor 2 at 4.5 m





Receptor 7 at 4.5 m





Substation at 4.5 m





Substation at 4.5 m





TWP 102 and RR 122 at 1.5 m





TWP 102 and RR 122 at 3 m





TWP 102 and RR 123 at 1.5 m





TWP 102 and RR 123 at 3 m





East Access Road Intersection at 1.5 m



East Access Road Intersection at 3 m



South Access Road Intersection at 1.5 m



South Access Road Intersection at 3 m

