

Connection Order 24636-D03-2019

Appendix 2 to Decision 24636-D01-2019	October 1, 2019
Burdett Solar GP Corp. Connect Burdett Solar Project to FortisAlberta Inc.'s 25-Kilovolt Distribution System	Proceeding 24636 Application 24636-A001

Burdett Solar GP Corp., by Application 24636-A001, registered on June 11, 2019, applied to the Alberta Utilities Commission for an order to connect the Burdett Solar Project to FortisAlberta Inc.'s existing 25-kilovolt distribution system.

The Commission approved the application in Decision 24636-D01-2019,¹ and granted Burdett Solar an order to connect the Burdett Solar Project to FortisAlberta Inc.'s 25-kilovolt distribution system, pursuant to Section 18 of the *Hydro and Electric Energy Act*. This approval is subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. Burdett Solar may connect the power plant to the distribution system in the southeast quarter of Section 15, Township 10, Range 12, west of the Fourth Meridian, as indicated in the application.
2. The specifications of the connection shall be as set out in the application.
3. The connection shall be operated so that except under short-term emergency conditions:
 - (a) The flows of real and reactive power are those for which the connection is designed and which it is intended to carry on a continuous basis.
 - (b) No excessive surges of 60-hertz power or excessive exchange of power frequency harmonics shall occur between the systems connected.

¹ Decision 24636-D01-2019: Burdett Solar GP Corp. – Burdett Solar Project Amendment and Time Extension, Proceeding 24636, Application 24636-A001, October 1, 2019.

4. This order is not transferable unless approved by the Commission.

The Commission may cancel or suspend this order, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this order, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, within 30 days of the date of this order and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected order on its website.

Alberta Utilities Commission

(original signed by)

Tracee Collins
Commission Member